



NOTES:

1. DUCTILE IRON PIPE FOR WATER MAINS SHALL BE BEDDED IN ACCORDANCE WITH ANSI/AWWA C150/A21.50 AND ANSI/AWWA C151/A21.51, TYPE 2 LAYING CONDITION.
2. MINIMUM DEPTH OF COVER SHALL BE 4'-0" UNLESS OTHERWISE APPROVED BY HCWSA.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**WATER LINE
TRENCH DETAIL**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

W02