



**NOTES:**

1. ALL FITTINGS AND VALVES AND THE FIRST 4 JOINTS OF PIPE FROM THE FIRE HYDRANT SHALL BE RESTRAINED.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**FIRE HYDRANT IN  
CUL-DE-SAC**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

**W05**