



NOTES:

1. ALL FITTINGS AND VALVES AND THE FIRST 4 JOINTS OF PIPE FROM THE FIRE HYDRANT SHALL BE RESTRAINED.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**FIRE HYDRANT AT
DEAD END**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

W06