



NOTES:

1. HCWSA WILL PROVIDE RESIDENTIAL WATER METERS AND BACKFLOW PREVENTERS. ALL OTHER APPURTENANCES SHALL BE PROVIDED BY THE DEVELOPER AND/OR CONTRACTOR.
2. WATER METER BOX LIDS SHALL HAVE 2-INCH DIAMETER HOLE OFFSET FOR TOUCH READ INSTALLATION.
3. EACH SERVICE SHALL BE MARKED WITH A "W" SAW CUT INTO TOP OF CURB AND PAINTED BLUE.
4. INSERT A 4-FOOT LONG PIECE OF 1" PVC PIPE THROUGH THE HOLE IN THE METER BOX LID TO MARK THE METER LOCATION. PAINT PVC PIPE BLUE.
5. NO PERMANENT STRUCTURES SHALL BE LOCATED WITHIN 5 FEET OF WATER SERVICE.
6. TYPICAL INSTALLATION MAY BE MODIFIED AT DISCRETION OF HCWSA.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**RESIDENTIAL WATER
METER DETAIL**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

W14