



NOTES:

1. ALL BURIED VALVES AND FITTINGS SHALL HAVE MJ FLANGES AND SHALL BE RESTRAINED WITH RESTRAINED JOINT GLANDS.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**10" OMNI F2 COMPACT
FIRELINE METER**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

W18