



**NOTES:**

1. PIPE USED FOR CREEK CROSSINGS SHALL BE DUCTILE IRON PIPE. JOINTS SHALL BE RESTRAINED FOR A MINIMUM OF 20 FEET BEYOND TOP OF BANK ON EACH SIDE OF CREEK.
2. CASING PIPE IS REQUIRED WHEN DEPTH OF COVER IS LESS THAN 3 FEET.
3. REFER TO DETAIL S16 FOR CASING DIAMETER.
4. PLACE STONE RIP-RAP APPROXIMATELY 5 FEET UPSTREAM AND 5 FEET DOWNSTREAM FROM CENTERLINE OF PIPE ALONG CREEK BED.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**CREEK CROSSING**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

**S17**