



NOTES:

1. ALL JOINTS AROUND EXISTING AND PROPOSED SEWER LINE SHALL BE GROUTED WATERTIGHT.
2. AFTER DOGHOUSE MANHOLE CONSTRUCTION IS COMPLETE, TOP HALF OF EXISTING SEWER LINE SHALL BE CUT OUT USING A METHOD APPROVED BY THE HCWSA INSPECTOR.
3. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE BOLT-DOWN LIDS.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**SANITARY SEWER
DOGHOUSE MANHOLE**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

S09