



NOTES:

1. OUTSIDE DROPS REQUIRED WHEN INSIDE DROP IS GREATER THAN 2 FEET.
2. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE BOLT-DOWN LIDS.
3. PIPE ENCASED IN CONCRETE SHALL BE WRAPPED WITH MINIMUM 10 MIL PLASTIC.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

SANITARY MANHOLE WITH OUTSIDE DROP

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.
S08