



NOTES:

1. MANHOLES LOCATED OUTSIDE OF PAVEMENT SHALL HAVE BOLT-DOWN LIDS.
2. MANHOLES SHALL HAVE A MINIMUM DROP OF 0.10 FEET FROM INFLUENT INVERT TO EFFLUENT INVERT.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**STANDARD SANITARY
SEWER MANHOLE**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

S07