



NOTES:

1. SDR 35/ SDR 26 POLYVINYL CHLORIDE (PVC) PIPE FOR SANITARY SEWER GRAVITY LINES SHALL BE BEDDED IN ACCORDANCE WITH AWWA C605, TYPE 5 LAYING CONDITION.
2. MAXIMUM DEPTH OF COVER SHALL BE 16'-0".



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**SDR 35/SDR 26
GRAVITY SEWER
TRENCH DETAIL**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

S05