



**NOTES:**

1. DUCTILE IRON PIPE FOR SANITARY SEWAGE FORCE MAINS SHALL BE BEDDED IN ACCORDANCE WITH ANSI/AWWA C150/A21.50 AND ANSI/AWWA C151/A21.51, TYPE 3 LAYING CONDITION.
2. MINIMUM DEPTH OF COVER SHALL BE 5'-0" UNLESS OTHERWISE APPROVED BY HCWSA.
3. TRACER WIRE SHALL BE INSTALLED ON ALL SANITARY SEWAGE FORCE MAINS.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**DUCTILE IRON SANITARY  
SEWAGE FORCE MAIN  
TRENCH DETAIL**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

**S02**