



NOTES:

1. SERVICE LINES SHALL BE STUBBED OUT TO 17 FEET BEHIND THE BACK OF CURB AND SHALL BE NO MORE THAN 10 FEET DEEP.
2. A WATER TIGHT CAP SHALL BE INSTALLED ON THE END OF THE LINE.
3. SERVICE LINES HAVING LESS THAN 5 FEET OF COVER SHALL BE DUCTILE IRON PIPE.
4. PLUMBING CONTRACTOR SHALL TIE ON TO SERVICE LINE USING STANDARD PVC FITTINGS OR "DONUT" CONNECTION.



HENRY COUNTY WATER & SEWERAGE AUTHORITY

**SEWER SERVICE LINE
LATERAL**

REVISED: 01/01/2012

SCALE: N.T.S.

DETAIL NO.

S18